


Test Verification of Conformity

Verification Number: 210302558SHA-V1

On the basis of the referenced test report(s), sample(s) tested of the below product have been found to comply with the standards harmonized with the directives listed on this verification at the time the tests were carried out. Other standards and Directives may be relevant to the product. This verification is part of the full test report(s) and should be read in conjunction with it <them>.

Once compliance with all product relevant  mark directives are verified, including any relevant e.g. risk assessment and production control, the manufacturer may indicate compliance by signing a Declaration of Conformity themselves and applying the mark to products identical to the tested sample(s).

Applicant Name & Address:	ZHEJIANG ETEK ELECTRICAL TECHNOLOGY CO., LTD. No. 288 Wei 17th Road, Yueqing Economic Development Zone, Yueqing, Wenzhou, Zhejiang, China
Manufacturing site Name & Address:	Hangzhou Taimu Electrical Co., Ltd. No. 157 Longchuanwu Road, Yuhang Economic Development Area, Hangzhou, China
Product Description:	Circuit-breakers for overcurrent protection for household and similar installations (CBOs)
Ratings & Principle Characteristics:	$U_n = 240/415V \sim (1P), 415V \sim (2P, 3P, 4P), 50/60Hz$ $I_n = 1, 2, 3, 4, 6, 10, 13, 16, 20, 25, 32, 40, 50, 63A; B-, C- and D-Type$ $I_{cs} = I_{cs} = 6000A, \text{Energy limiting class 3 (Only for B-, C- Type)}$
Models/Type References:	EKM2-63
Brand Name(s):	
Standard(s)/Directive(s):	EN 60898-1:2019 Low Voltage Directive 2014/35/EU
Verification Issuing Office Name & Address:	Intertek Testing Services Shanghai Building No.86, 1198 Qinzhou Road (North), Shanghai 200233, China
Date of Tests:	2020-10-26 to 2020-12-02
Test Report Number(s):	210302558SHA-001



Signature

Name: Oliver Wei
Position: Manager
Date: 13 May 2021