

## Test Verification of Conformity

## Verification Number: 210302557SHA-V1

On the basis of the referenced test report(s), sample(s) tested of the below product have been found to comply with the standards harmonized with the directives listed on this verification at the time the tests were carried out. Other standards and Directives may be relevant to the product. This verification is part of the full test report(s) and should be read in conjunction with it <them>.

Applicant Name & Address: ZHEJIANG ETEK ELECTRICAL TECHNOLOGY CO., LTD.

No. 288 Wei 17th Road, Yueqing Economic Development Zone, Yueqing,

Wenzhou, Zhejiang, China

Manufacturing site Name &

Address:

Hangzhou Taimu Electrical Co., Ltd.

No. 157 Longchuanwu Road, Yuhang Economic Development Area, Hangzhou,

China

Product Description: Circuit-breakers for overcurrent protection for household

and similar installations (CBOs)

Ratings & Principle

Characteristics:

 $U_n$ = 240/415V~ (1P), 415V~ (2P, 3P, 4P)

 $I_n$ = 1, 2, 3, 4, 6, 10, 16, 20, 25, 32, 40, 50, 63A; B-, C- and D- Type

 $I_{cn}$ = 10000A,  $I_{cs}$ = 7500A, Energy limiting class 3, 50/60Hz

Models/Type References: EKM2-63H

Brand Name(s):

**ETJK** 

Standard(s)/Directive(s):

EN 60898-1:2019

Low Voltage Directive 2014/35/EU

Verification Issuing Office

Name & Address:

Intertek Testing Services Shanghai

Building No.86, 1198 Qinzhou Road (North), Shanghai 200233, China

Date of Tests:

2020-10-26 to 2021-05-25

Test Report Number(s):

210302557SHA-001

Signature

Name: Oliver Wei Position: Manager Date: 15 June 2021

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification, any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.